

Certificate of conformity with the following European Directives

Registered No.:

1608604724E/M18/46119

Machinery Directive 2006/42/EC

Reference of applicant	Date of application	File reference	Test report No.	Date of issue	Expire date
7909	2016-08-22	7909-WT_IQ/M1	1608604724E/45076/TR/18	2018-09-17	2023-09-16

This is to certify that the following products comply to the essential requirements of the above mentioned European Directive and the following standards:

Product: Air Handling Unit (for HVAC)

Type designation: IQ-X00-XXXX-000. (Models differences, see Annex 1)

Applicant: Well Technology OÜ
21004, Kadastiku tänav 45B, Narva, Estonia.

Standard(s): LVS EN 60204-1:2006 + A1:2009 Safety of machinery - Electrical equipment of machines - Part I: General requirements.
LVS EN ISO 12100:2011 Safety of machinery - General principles for design - Risk assessment and risk reduction (ISO 12100:2010).

This Certificate of conformity is based on the evaluation of samples of the product. It does not imply an assessment of the production and it does not permit the use of a mark of conformity or of a safety mark of the TUV NORD Group. This is to certify that the tested sample is in compliance with the essential requirements referred to Machinery Directive 2006/42/EC. The holder of this certificate may use this Certificate together with his EC-Declaration of Conformity.


/ J Rače /
Certification Body of TUV NORD Baltik LLC

TUV NORD Baltik LLC
Reg No 40003121062
3 Saremas Street, Riga,
Latvia, LV 1005
Phone +371-67370391
E-mail: info@tuv-nord.lv,
www.tuv-nord.lv

 The CE marking may be affixed on the product if all relevant and effective Directives are complied with. 

N^o 000955

Description of product(s):

400 V~, 50 Hz, Class I, (- 40...+ 40) °C.

Model IQ -X 00 - XXXX -000

Series of Air Handling Unit:

3- Flow Rate 1900...52800 m³/h;
 5- Flow Rate 1700...60600 m³/h;
 7- Flow Rate 39600...121100 m³/h.

Application scope:

00- For standard residential and industrial buildings.

Cross-sectional frontal index (overall size H x W, mm):

MODEL IQ300	MODEL IQ500	MODEL IQ700
0019 - (450 x 700)	0019 - (750 x 465)	0454- (2300 x 2600)
0039 - (800 x 700)	0034 - (500 x 900)	0543- (2600 x 2300)
0058 - (800 x 1000)	0039 - (810 x 750)	0571- (2300 x 2900)
0078 - (800 x 1300)	0054 - (675 x 1095)	0623- (2600 x 2600)
0087 - (1090 x 1000)	0058 - (810 x 1050)	0744- (2300 x 3500)
0097 - (800 x 1600)	0078 - (810 x 1350)	0779- (2600 x 3200)
0117 - (1090 x 1300)	0086 - (1020 x 1050)	0880- (2300 x 4100)
0156 - (1400 x 1300)	0097 - (810 x 1650)	0935- (2600 x 3800)
0193 - (1400 x 1600)	0115 - (1020 x 1350)	
0234 - (1400 x 1900)	0116 - (1320 x 1050)	
0289 - (1700 x 1900)	0138 - (1020 x 1680)	
0350 - (2000 x 1900)	0156 - (1320 x 1350)	
0407 - (2000 x 2200)	0173 - (1020 x 1950)	
	0193 - (1320 x 1650)	
	0194 - (1620 x 1350)	
	0215 - (1120 x 2135)	
	0234 - (1320 x 1950)	
	0240- (1620 x 1650)	
	0271 - (1320 x 2250)	
	0289 - (1620 x 1950)	
	0290 - (1920 x 1650)	
	0333 - (1320 x 2550)	
	0337 - (1620 x 2250)	
	0350 - (1920 x 1950)	
	0407 - (1920 x 2250)	
	0414 - (1620 x 2550)	
	0473 - (2250 x 2250)	
	0500 - (1920 x 2550)	

Options:

000 – Standard, without special requirements.

 / J. Rače /
 Certification Body of TUV NORD Baltik LLC

TUV NORD Baltik LLC
 Reg No 40003121062
 3 Saremas Street, Riga,
 Latvia, LV 1005
 Phone +371-67370391
 E-mail: info@tuv-nord.lv,
 www.tuv-nord.lv